



Future European Heat

Renewable heating comparisons

Tuesday, 28 May 2013

By: Melahn Parker (Melahn.Parker@dnvkema.com)

DNV KEMA Energy & Sustainability



DNV KEMA serves the entire energy industry

Exploration
&
Production

Transport &
Distribution

Use

Policy,
Strategy &
Trade



Providing guidance, direction, evidence and support to manage opportunities and risk in changing and complex energy markets

To help our clients successfully anticipate market developments and make strategic business decisions

We combine in-depth knowledge of international markets, technologies, and best practices with analytical skills to advise across the entire energy value chain

DNV KEMA – Future Energy Systems

- Pathway analysis to achieve business and environmental goals
 - End user demand
 - Electricity, Heating, Hot Water, Cooling
 - Conversion technologies
 - Boiler, Heat Pumps, PV, Wind, Central Fossil plants, etc.
 - Supply and delivery of primary energy
 - Production, Transmission, Distribution



- Energy policy development and evaluation
- Technology (development) assessments
- Energy market design and network access
- Market rules and technical codes
- Investment Decision Support & Benchmarking





Rowhouse electric demand – gas boiler to GHP

- On cold winter day (-12°C), shift from gas boiler to GHP increases peak load 200%
- On moderate winter day (0°C), shift from gas boiler to GHP doubles peak load

Household electric demand kW

Household electric demand kW

Increase in heating for cold day from 0 to -12°C







NL built environment demand under two scenarios

- Electric scenario increases demand 33% over mixed scenario in 2050 (+20 TWh/yr)
- Peak load in all electric scenario is 61% higher than mixed scenario (+7.5 GW_e)

Electricity demand TWh_e/yr



Peak load¹ GW_e



¹ Fixed load varies on peak 2050 day because the overall peak occurs on different days/times in each scenario
 Source: DNV KEMA analysis


Four business models to develop projects

- 1. Economic** driven projects benefit from acceptable returns without direct subsidy (though often there is still some subsidy)
 - Fuel switching to biomass from fuel oil (benefit from avoided taxes)
- 2. Subsidized** require a reduction in financed capital costs and/or a feed in tariff to ensure future revenues beyond market prices
 - Solar thermal district heating, biogas, and biomethane
- 3. Regulated** building efficiency standards can force new technologies
 - Ground source heat pumps, insulation, glazed windows, etc.
- 4. microFinance** allows individuals to aggregate and place their capital into projects that may not offer the returns required by the private sector, but:
 - 50% of consumers are willing to pay a <5% premium for RES
 - 10% of consumers are willing to pay a 5-10% premium for RES
 - Only 1% of consumers are willing to pay a >10% premium for RES


NL CO₂ intensity per heat delivered by technology

- Specific carbon emissions (kg CO₂/kWh) are assumed to decrease greatly by 2050 due to decarbonization of electricity mix and development of low carbon gases

Carbon emissions of fuel kg CO₂/kWh



Heat specific carbon emissions kg CO₂/kWh




Explanation of heat economic analysis assumptions

- Heat economic evaluation occurs in two stages:
 1. HOME Comparison (multi-kW_{th}), also with assumed DH networks¹
 2. DH Comparison (capacity of 10 MW_{th})
- Constant lifetime of 20 years and WACC² of 6% assumed across all options
 - Fuel prices are different for each scale and carbon intensity decreases to 2050 as follows:

Fuel	HOME price [€/kWh]	DH price [€/kWh]	Carbon intensity [kg CO ₂ /kWh]		
			2010	2030	2050
Electricity	20	10	0.458	0.137	0.030
Gas	6	4	0.185	0.148	0.118
Biomass	4	3	0.02	0.016	0.013
CHP heat	4	4	0.175	0.079	0.001

¹ DH heat supply price assumed 40 €/MWh_{th}; ² Weighted Average Cost of Capital;
Source: DNV KEMA analysis

Residential heat – economics and emissions




Heat cost

¢/kWh_{th}


7.9

Capex Opex Fuel




CO₂

gCO₂/kWh_{th}



Cost¹

EUR/tCO₂





Gas CHP heat price

¹ Carbon mitigation cost calculated by comparison to gas boiler for middle case of each technology with given year's fuel carbon intensity
Source: DNV KEMA analysis


District heat – economics and emissions

2010
2030
2050



Gas CHP heat price

1 Carbon mitigation cost calculated by comparison to gas boiler for middle case of each technology with given year's fuel carbon intensity
Source: DNV KEMA analysis




Geothermal CHP DH example – Germany

Landau

- 48% of heat load is met with geothermal which operates at ~67% capacity factor (utilization)¹
- ~20 million EUR total investment
- Geothermal water resource at 3,200 m depth and 155°C (50-70 l/s flow rate)
- ORC-process² for CHP (with back cooling for electricity generation outside heating season)

Commissioned	2007
CHP process	ORC ²
Aquifer temp	155
Drill depth	3,200m
MW _{th}	5.1
MW _e	3


Landau heat delivery to specific city area MWh_{th}



¹ Utilization accounts for lower heat capacity in summer due to CHP constraints (would be 58% using max winter heating capacity);

² Organic Rankine Cycle;


Source: Menzel: Geothermische Stromerzeugung in Landau 2007, Knappek: Geothermieprojekt Unterhaching 2007



Seasonal thermal storage – performance


- Performance of seasonal storage depends on storage technology and capacity of storage unit
- A large challenge is the reduced discharge temperature which has to be compensated by heat pumps or peak boilers, and is proportional to the storage loss

Water-tank energy storage balance¹
MWh/year Out/In %



12,000 m³ Hot water storage tank


Aquifer energy storage balance²
MWh/year Out/In %



Aquifer thermal energy storage


1 Example Friedrichshafen, 12,000 m³ concrete tank, installed 1997; 2 Example Reichstag-Building Berlin, installed 2002
Source: BINE Informationsdienst 2001

Combining geothermal and aquifer seasonal storage




- Requirements for the combination:
 - Appropriate geologic conditions for deep geothermal energy extraction and seasonal heat storage in an aquifer at the same place
 - Dimensioning of the deep geothermal system (flow rates) for approx. 60% of max. monthly heat load
 - Dimensioning of the aquifer storage system (flow rates) for approx. 70% of deep geothermal system
- Benefits:
 - Supply system with very high fraction (up to 100%) of renewable energy
 - High number of yearly utilization hours for both geothermal part systems
 - Utilization of deep geothermal resource up to 90%
- Challenge:
 - Heat for charging the aquifer is not free
 - Cost optimum must be found concerning dimension of deep geothermal probes, aquifer probes and peak load boiler

Load simulation of deep geothermal with aquifer storage for 100% heat supply



Solar DH – Brødstrup, Denmark (1/2)




Specifications¹

- Flat plates (8,012 m²) placed on ground
 - Operational since 2007 in combination with gas CHP/boilers and 2,000 m³ steel water tank
- Heat output:
 - 2011: 3.3 GWh/yr (380 kWh_{th}/m²/yr)
 - 2010: 3.0 GWh/yr (340 kWh_{th}/m²/yr)
 - ~39% efficient from 924 kWh_{solar}/m²/yr
- Delivers 7% of annual 42 GWh heat load

Economics


- Total investment of 1,640 k€
 - 205 €/m² solar collector area
 - Subsidies of 320 k€ (20% of capex)
 - Heating network already in place
- Operating cost of 0.66 €/MWh solar heat (~2 k€/yr)
- Cost of solar heat:²
 - Without subsidy: 55 €/MWh (25)
 - With subsidy: 45 €/MWh (21)

Monthly heat production MWh




¹ Brødstrup DH plant has recently been expanded with 10,000m² solar panels, 5,500m³ tank and 19,000 m³ of borehole storage, 10 MW E-boiler and heat pump ² Assumed WACC of 6% and 20 yr lifetime, values in (parenthesis) corresponds to 0% WACC
Source: Solvarmedata.dk 2011, SDH April 2009

Solar DH – Brædstrup, Denmark (2/2)



- Heat demand at night does not align with heat production during the day, and heat production is nearly negligible from Nov thru Feb when only 2% of heat is produced (13% comes in March and October)
- Thermal storage is required for DH networks with high solar contributions, but in this example solar only provides 7% of the annual demand¹, though this corresponds with ~26-43% of the summer heat demand²

Average hourly heat production per month in 2011³ MWh



1 Remaining heat provided by gas CHP and gas boilers; 2 Assumes space heating is from 50-70% of total heat demand;
 3 Data represents average hourly for each month
 Source: Solvarmedata.dk 2011