



Located in Yverdon, Switzerland

- Partner of 27 University Conglomerate Western Switzerland
- Employees : 660
- Students: 1500 (17% foreign)

## aR&D activities

Total budget: 55 – 70 Mio Euro

- R&D budget: 25%
- Organisation & Infrastructure for Tech Transfer

**Core competences and laboratory installations for applied research projects and industrial contracts:**

**> combustion, biogas, torrefaction and characterization of biomass**


## Activities in Torrefaction

- **Laboratory-scale torrefactor**
  - 5 kg/h screw electric heating, operational since 2012
- **Experimental combustion facility**
  - 50 kW experimental, operational since 2009
- **Tests with small scale oven**
  - 30 kW installed burner, performed in 2012




## Energy Consumption Target

- Heating demand decline - 1 %/a
- Power demand increase + 1 %/a
- Reduction of variation
- > Improve efficiency, storage cap & grid




## Solid Biofuel Prod. Plan

- Growth of solid biomass + 1 to 3 %/a
- Exploit solid biomass potential 733 TWh/a
- Increasing imports
- > New technique & application (CHP)



## Estimated utilization and potential

- Non used potential 50% to 80%
- Estimated potential 100 TWh/a (33 Mio to/a)
- Low price
- > Niche: High potential but low volume




## Existing Installation

- Forrest houses
- Incinerators
- Compost plant
- > Local, decentralized installations

## Chemical composition

- Reduction of hydrogen & humidity
- Small reduction of oxygen
- Small increase of carbon
- Constant ash content
- > Biggest change in humidity




## Physical properties, non densified

- Higher heating value + 70 to 80%
- Fewer volatiles – 10 to 20 %
- Lower bulk density – 40 to 50 %
- > Biggest change in heating value

	Wood logging residues	Torrefied wood logging residues	Bitumous coal
LHV [MJ/kg]	11	19	25
Volatiles [%]	80%	75%	55%
bulk density [kg/m <sup>3</sup> ]	350	225	700
energy density [MJ/m <sup>3</sup> ]	3 850	4 275	17 500


## Efficiency normal cond.

- (3) Humidity reduction: eff. + 15% - 30%
  - (2) Excess air reduction: eff. + 2% - 5%
  - (1) Higher temperature > incr. generation
- > Higher efficiency with improved fuel




## Efficiency with diff. temp.

- Regulation with condensing unit
  - Reduced ambient depends
- > Improved seasonal efficiency




## Cost sensitivities

- 1) Important effect of efficiency
- 2) Biomass
- 3) Torrefaction process
- > Combustion & fuel combination



## Heat production cost


- Torrefied residues are competitive
- Consideration of integration
- > Decentralized solutions feasible



Comparison	Torrefied Wood logging residues	Wood logging residues
Thermal efficiency	↑	↓
Condensing demand	↓	↑
Potential corrosion	↓	↑
Emission	↓	↑


## Energy generation combinations


- 2 Combustion types
  - 3 Energy generation types
  - 2 Energy distribution systems
- > EU measures: increase CHP, DH, multi-biomass




## Installed Capacity

- Main Fuel: wood chips
  - Main Application: small scale, grate
- > New technique & application (CHP)






## Characteristics




## General fuel range of use



## Fixed O&M + Invest

- Grate firing most economic
- FB: higher O&M cost
- Ash removal same (...sand)
- > Grate firing for boiler operation



## Electricity production cost

- Fluidized bed more efficient
- Broad range
- > Depends on specific case

	Electricity production cost [€/kWh]
grate boiler	0,04€ - 0,16€
CFB&BFB boiler	0,05€ - 0,16€
grate CHP	0,05€ - 0,22€

<b>Comparison</b>	<b>BFB</b>	<b>CFB</b>	<b>Grate firing</b>
Fuel Range	Limited	Unlimited	Unlimited
Small scale	No	No	Yes
efficiency	Higher	Higher	Lower
Total operation cost	Higher	Higher	Lower

## Advantages of torrefied wood logging residues

- High efficiency
- High potential for co-gen due to higher temperature
- Minimum condensation requirement
- > Next step: confirm with tests

## Potential application for torrefied wood logging residues

- Small to medium scale < 20 MW: grate
- Low Combustion unit investment costs
- Low Combustion operation costs
- > Depends on application, potential to improve all existing installations